

3"- 6" PE-SERIES VERTICAL DRY PIT CHOPPER PUMPS

Materials of Construction:

Impeller/Cutter Nut /Upper Cutter: Cast alloy steel, heat treated to minimum Rockwell C 60.

Casing/Back Pull-Out Plate: Ductile cast iron.

sleeve. (See following page for other sealing options)

Thrust Bearings: Back-to-back angular contact ball type or face to face tapered roller type.

Radial Bearings: Ball type or cylindrical roller type.

Shaft: Heat treated alloy steel.


Lubrication: ISO Grade 46 oil.

Mounting Base: Carbon Steel.


Paint: Ceramic Epoxy.

DRAWINGS AND DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE. DO NOT USE FOR CONSTRUCTION PURPOSES. CONTACT VAUGHAN FOR CERTIFIED CONSTRUCTION PRINTS.

DIMENSIONS IN INCHES



MODEL	Α	В	С	D	Е	F	G	Н
PE3F/PE3G	38-7/16	6-1/4	12-1/2	10	7-5/8	6	3	*20
PE3L/PE3M	37-9/16	6-1/4	12-1/4	10	8-5/8	6	3	*20
PE3P	37-1/2	6-1/4	11-3/4	10	11	6	3	*20
PE3V/PE3W	37-5/8	6-1/4	11-3/4	10	8-7/8	6	3	*20
PE4K/PE4L	38-15/16	6-1/4	12-7/8	10	9-1/2	6	4	*20
PE4S/PE4T	38-1/16	6-1/4	12-3/4	10	11-1/2	6	4	*20
PE4V	47	11	15-15/16	13-1/8	17	8	4	29
PE6X/PE6W	46-15/16	11	16-5/16	13-1/8	13-1/2	8	6	29



	5	1750	184TC	23	10
١	7.5	1170	254TC	30	13
	1.5	1750	213TC	25	11
	10	1170	256TC	32	13
		1750	215TC	26	11
		1170	284TC	33	15
	15	1750	254TC	30	13
		3510	254TC	30	13
		1170	286TC	34	15
	20	1750	256TC	32	13
		3510	256TC	32	13
		1170	324TC	36	17
	25	1750	284TC	33	15
		3510	256TC	32	13
		1170	326TC	38	17
	30	1750	286TC	33	15
		3510	284TSC	33	15
		1170	364TC	40	19
	40	1750	324TC	36	17
		3510	286TSC	28	15
		1170	365TC	40	19
	50	1750	326TC	38	17
		3510	326TSC	34	17
		1170	404TC	45	22
	60	1750	364TC	40	19
Į		3510	364TSC	38	19

HP SPEED FRAME

**U

215TC

*IF MOTOR FRAME SIZE IS 324TC OR LARGER DIMENSION IS 23"

**FOR REFERENCE ONLY, DIMENSION WILL VARY SLIGHTLY BY MOTOR MANUFACTURER

VAUGHAN CO., INC.



364 Monte Elma Road, Montesano, WA 98563 Phone: 1-360-249-4042 / Fax: 1-360-249-6155 Toll Free Phone (US only): 1-888-249-CHOP (2467) Web Site: www.chopperpumps.com

Company E-mail: info@chopperpumps.com
For all current patents, please see http://www.chopperpumps.com/patents.htm

MADE IN THE

405TC

365TC

45

40 19

22

1170

1750

75



SPECIFICATIONS, 3"- 6" VERTICAL DRY PIT CHOPPER PUMPS

The vertical dry pit chopper pump shall be specifically designed to pump waste solids at heavy consistencies without plugging or dewatering of the solids. Materials shall be chopped/macerated and conditioned by the pump as an integral part of the pumping action. The pump must have demonstrated the ability to chop through and pump high concentrations of solids such as plastics, heavy rags, grease and hair balls, wood, paper products and stringy materials without plugging, both in tests and field applications. Pump shall be manufactured by Vaughan Co., Inc.

DETAILS OF CONSTRUCTION

- A. Casing and Back Pull-Out Plate: The pump casing shall be of volute design, spiraling outward to the Class 125 flanged centerline discharge. Back pull-out design shall incorporate jacking bolts for accurate adjustment of impeller-to-cutter bar clearance, and shall allow removal of pump components without requiring disconnection of casing from inlet or discharge piping. Casing & backplate shall be ductile cast iron with all water passages to be smooth, and free of blowholes and imperfections for good flow characteristics. A pressure tap shall be included on or near the discharge flange. Backplate shall include a replaceable Rockwell C 60 alloy steel cutter adjustable for 0.005-0.050" clearance to cut against the rotating impeller pumpout vanes for removing fiber and debris.
- B. Impeller: Shall be semi-open type with pump out vanes to reduce seal area pressure. Chopping/maceration of materials shall be accomplished by the action of the cupped and sharpened leading edges of the impeller blades moving across the cutter bar at the intake openings, with a set clearance between the impeller and cutter bar of 0.015-0.025" cold. Impeller shall be cast alloy steel heat treated to minimum Rockwell C 60 and dynamically balanced. The impeller shall be keyed to the shaft and shall have no axial adjustments and no set screws.
- C. Cutter Bar Plate: Shall be recessed into the pump bowl and shall contain at least 2 shear bars extending diametrically across the intake opening to within 0.010-0.030" of the rotating cutter nut tooth, for the purpose of preventing intake opening blockage and wrapping of debris at the shaft area. Chopper pumps utilizing individually mounted shear bars shall not be acceptable. Cutter bar shall be cast alloy steel or alloy steel heat-treated to minimum Rockwell C 60.
- D. Cutter Nut: The impeller shall be secured to the shaft using a cutter nut, designed to cut stringy materials and prevent binding using a raised, rotating cutter tooth. The cutter nut shall be cast alloy steel heat treated to minimum Rockwell C 60.
- E. Upper Cutter: Shall be threaded into the back pull-out adapter plate behind the impeller, designed to cut against the pump-out vanes and the impeller hub, reducing and removing stringy materials from the mechanical seal area. Upper cutter shall be cast alloy steel heat treated to minimum Rockwell C 60. The upper cutter teeth are positioned as closely as possible to the center of shaft rotation to minimize cutting torque and nuisance motor tripping. The ratio of upper cutter cutting diameter to shaft diameter in the upper cutter area of the pump shall be 3.0 or less.
- F. Pump Shafting: Shall be heat treated alloy steel.
- G. Bearings: Shall be oil-bath lubricated with ISO Grade 46 oil. Shaft thrust in both directions shall be taken up by two back-to-back mounted single-row angular contact ball bearings or two face to face mounted tapered roller bearings. Two adjacently mounted single-row radial bearings or one cylindrical roller type shall also be provided. L-10 bearing life shall be minimum 100,000 hours.
- H. Bearing Housing: Shall be ductile cast iron and machined with piloted bearing fits for concentricity of all components. Bearing housing shall include a side-mounted oil reservoir. Viton® double lip seals riding on stainless steel shaft sleeves are to provide sealing at each end of the bearing housing. Thrust bearings are mounted in an adjustable cartridge to allow external upper cutter adjustment.
- Stuffing Box: Shall be ductile cast iron. The stuffing box shall be designed to accommodate the mechanical seal, or packing. Mechanical seal with no seal water flush and flushed tandem mechanical seal as described below do not require stuffing box.
- J. Seal: [NOTE TO CONSULTING ENGINEER]: Please choose one of the four options below:
 - Mechanical Seal system specifically designed to require no seal flush: The mechanical seal shall be located immediately behind the
 impeller hub to eliminate the stuffing box and maximize the flushing available from the impeller pumpout vanes. The seal shall be a
 cartridge-type mechanical seal with Viton O-rings and silicon carbide (or tungsten carbide) faces. This cartridge seal shall be preassembled, and pre-tested so that no seal settings or adjustments are required from the installer. Any springs used to push the seal
 faces together must be shielded from the fluid to be pumped. The cartridge shall also include a 17-4PH, heat-treated seal sleeve
 and stainless steel seal housing.
 - Flushed Tandem Mechanical Seal: The seal shall be cartridge-type tandem mechanical seal with Viton O-rings and silicon carbide (or tungsten carbide) faces. This cartridge seal shall be a pre-assembled and pre-tested so that no seal settings or adjustments are required from the installer. Any springs used to push the seal faces together must be shielded from the fluid to be pumped. The cartridge shall also include a 17-4PH, heat-treated seal sleeve and stainless steel seal housing. Seal requires flush to drain at 3 US gallons per hour flow rate.
 - Mechanical seal with throttle bushing and water fitting for seal water flush. The seal shaft sleeve shall be AISI 316 SS. Mechanical seal materials shall be 316 stainless steel or Alloy 20 with silicon carbide or tungsten carbide faces. Seal shall be positively driven by set-screws. Elastomers shall be of Buna N, and stationary seal member shall be of the cup-mounted type to ensure cushioning of face material from mechanical shock. Contractor is to provide a 6-10 gal./hr. seal flush with filtered water, a rotameter, throttle valve, and solenoid operated isolation valve interlocked with an auxiliary contact of the motor starter.
 - Packing design with 5-ring Kevlar packing split Teflon lantern ring and water fitting. The packing shaft sleeve shall be 316 SS with Nickel-Chrome-Boron coating. Contractor is to provide a filtered water packing flush at 10 PSI greater than pump discharge pressure. The flush water line is to be interlocked with an auxiliary contact of the motor starter so it is automatically turned on when the motor is started.
- K. Inlet Manifold: The pump assembly shall be mounted vertically on a 90 degree carbon steel elbow with a Class 150 inlet flange, cleanout, 1/4" NPT suction pressure tap, drain connection and pedestal base.
- L. Shaft Coupling: Bearing housing and motor stool design is to provide accurate, self-aligning mounting for a C-flanged electric motor. Pump and motor coupling shall be T.B. Woods Sureflex elastomeric type.
- M. Stainless Steel Nameplate: Shall be attached to the pump giving the manufacturer's model and serial number, rated capacity, head, speed and all pertinent data.
- N. Motor Requirements: Drive motor shall be ____ HP, ____ RPM, ____ volts, 3 phase, 60 hertz,1.15 service factor, C-flange mounted, TEFC enclosure. The motor shall be sized for non-overloading conditions.
- O. Surface Preparation: Solvent wash and a single coat of Tnemec 431 epoxy applied at 5 MDFT minimum (except motor).
- P. OPTIONAL Surface Preparation: SSPC-SP6 commercial sandblast (except motor), a prime coat of Tnemec 431 epoxy and a finish coat of Tnemec 431 epoxy for total finish of 30 MDFT minimum (except motor).