


3" - 6" HORIZONTAL STAINLESS STEEL SCREW CENTRIFUGAL PUMPS

Materials of Construction:

Impeller/Casing/Suction Cone: 316 stainless steel or better
Back Plate: CD4MCu stainless steel.
Flushless Mechanical Seal: Cartridge type with stainless steel sleeve and housing with silicon carbide (or tungsten carbide) faces. (See following page for other sealing options)
Thrust Bearings: Face to face tapered roller type.
Radial Bearings: Ball bearing type.
Shaft: 316 stainless steel.
Lubrication: ISO 46 hydraulic oil.
Flanges: ANSI Class 125
Mounting Base: Carbon Steel.
Paint: Epoxy.

DRAWINGS AND DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE. DO NOT USE FOR CONSTRUCTION PURPOSES. CONTACT VAUGHAN FOR CERTIFIED CONSTRUCTION PRINTS.



DIMENSIONS IN INCHES

MODEL	A	B	C	D	E	F	G
HSC3DS	6 ¹ / ₂	12 ⁷ / ₈	- ¹ / ₂	8 ⁵ / ₈	58 ¹ / ₂	4	3
HSC4DH	7 ¹ / ₈	12 ⁷ / ₈	1 ³ / ₁₆	9 ³ / ₄	60 ³ / ₁₆	4	4
HSC6EM	9 ⁵ / ₈	15 ¹ / ₁₆	3	12 ¹⁵ / ₁₆	62	6	6&5
HSC6ES	9 ⁵ / ₈	15 ¹ / ₁₆	3	12 ¹⁵ / ₁₆	62	6	6&5

MOTOR FRAME SIZE	*U	*V
184TC	23	10
213TC	25	11
215TC	26	11
254TC	30	13
256TC	32	13
284TC	33	15
286TC	34	15
324TC	36	17
326TC	38	17

*FOR REFERENCE ONLY. DIMENSIONS WILL VARY SLIGHTLY BY MOTOR MANUFACTURER



VAUGHAN CO., INC.
 364 Monte Elma Road, Montesano, WA 98563
 Phone: 1-360-249-4042 / Fax: 1-360-249-6155
 Toll Free Phone (US only): 1-888-249-CHOP (2467)
 Website: www.chopperpumps.com
 Company E-mail: info@chopperpumps.com

For all current patents, see <https://www.chopperpumps.com/patents/>

**MADE IN THE
USA**

SPECIFICATIONS: 3"- 6" STAINLESS STEEL HORIZONTAL SCREW CENTRIFUGAL PUMPS

The Vendor shall furnish () horizontal, screw-centrifugal pump(s) and all appurtenances as specified below. The pump(s) shall be of heavy-duty construction intended for services requiring reliable solids handling, gentle pumping action, high efficiency, and low NSPHR. Pump shall be manufactured by Vaughan Co., Inc.

DETAILS OF CONSTRUCTION:

- A. Casing and Back-plate:** The pump casing shall be of volute design, spiraling outward to the Class 125 flanged centerline discharge. Casing shall be cast 316 stainless steel or better with all water passages to be smooth, and free of blowholes and imperfections for good flow characteristics. A pressure tap shall be included on or near the discharge flange. Back pull-out design shall incorporate adjusting sleeves for accurate adjustment of impeller-to-suction cone clearance, and shall allow removal of pump components without requiring disconnection of casing from inlet or discharge piping. Back-plate shall be CD4MCu and will include a cutter groove to cut against the opposing impeller hub cutter groove for removing fiber and debris.
- B. Inlet Suction Cone:** The inlet suction cone shall be cast 316 stainless steel or better with all water passages to be smooth, and free of blowholes and imperfections for good flow characteristics. The suction cone shall incorporate a spiral groove to channel trapped fiber into the casing that would otherwise bind between the impeller OD and the inlet cone ID. The clearance of impeller to inlet cone shall be externally adjustable without requiring special tools, pump disassembly or disconnection of piping.
- C. Impeller:** Shall be open channel, screw-centrifugal supported by tapered roller bearings and ball bearings. The impeller shall be cast 316 stainless steel or better and shall be dynamically balanced. The single-passage impeller shall combine the action of a positive displacement screw and a single-vane centrifugal impeller.
- D. Impeller Hub:** Shall be CD4MCu. Cutter groove clearance from the back-plate cutter groove shall be externally adjustable without requiring pump disassembly or special tools.
- E. Pump Shafting:** Shafting shall be 316 stainless steel supported by tapered roller bearings and ball bearings.
- F. Stuffing Box:** Shall be cast 316 stainless steel or better. The stuffing box shall be designed to accommodate the mechanical seal, or packing. Mechanical seal with no seal water flush and flushed tandem mechanical seal as described below do not require stuffing box.
- G. Seal:** [NOTE TO CONSULTING ENGINEER: Please choose one of the four options below]:
- Mechanical Seal system specifically designed to require no seal flush: The mechanical seal shall be located immediately behind the impeller hub to eliminate the stuffing box and maximize the flushing available from the impeller pumpout vanes. The seal shall be a cartridge-type mechanical seal with Viton O-rings and silicon carbide (or tungsten carbide) faces. This cartridge seal shall be a pre-assembled, and pre-tested so that no seal settings or adjustments are required from the installer. Any springs used to push the seal faces together must be shielded from the fluid to be pumped. The cartridge shall also include a 17-4PH, heat-treated seal sleeve and stainless steel seal housing.
 - Flushed Tandem Mechanical Seal: The seal shall be cartridge-type tandem mechanical seal with Viton O-rings and silicon carbide (or tungsten carbide) faces. This cartridge seal shall be a pre-assembled and pre-tested so that no seal settings or adjustments are required from the installer. Any springs used to push the seal faces together must be shielded from the fluid to be pumped. The cartridge shall also include a 17-4PH, heat-treated seal sleeve and stainless steel seal housing. Seal requires flush to drain at 3 US gallons per hour flow rate.
 - Mechanical seal with throttle bushing and water fitting for seal water flush. The seal shaft sleeve shall be 316 stainless steel. Mechanical seal materials shall be either 316 stainless steel or Alloy 20 with silicon carbide or tungsten carbide faces. Seal shall be positively driven by set-screws. Elastomers shall be of Buna N, and stationary seal member shall be of the cup-mounted type to ensure cushioning of face material from mechanical shock. Contractor is to provide a 6-10 gal./hr. seal flush with filtered water, a rotameter, throttle valve, and solenoid operated isolation valve interlocked with an auxiliary contact of the motor starter.
 - Packing design with 5-ring packing, split Teflon lantern ring and water fitting. The packing shaft sleeve shall be 316 stainless steel with Nickel-Chrome-Boron coating. Contractor is to provide a filtered water packing flush at 10 PSI greater than pump discharge pressure. The flush water line is to be interlocked with an auxiliary contact of the motor starter so it is automatically turned on when the motor is started.
- H. Bearings:** Shaft thrust in both directions shall be taken up by two face to face mounted single-row tapered roller bearings. Ball bearings shall be provided for radial loads. Bearings shall be rated with a minimum L-10 bearing life of 100,000 hours at any acceptable operating point on the performance curve.
- I. Bearing Housing:** Shall be ductile cast iron, and machined with piloted bearing fits for concentricity of all components. Bearing housing shall have oil bath lubrication using ISO 46 hydraulic oil and will include an oil level sight glass. Fill and drain ports shall be provided. Bronze non-contacting labyrinth style, O-ring mount bearing isolators shall be provided at each end of the bearing housing to prevent egress of oil and ingress of contaminants. Bearing housing shall include a cast-in lifting eye to aid in removing the back-pullout assembly from the pump casing during maintenance.
- J. Shaft Coupling:** Bearing housing and motor stool design is to provide accurate, self-aligning mounting for a C-flanged electric motor. Pump and motor coupling shall be T.B. Woods Sureflex elastomeric type.
- K. Optional Belt Drive:** Adjustable brackets shall be used to support an over-head or side mounted motor. Sheaves and belts shall be properly sized for horsepower ratings, and all guards are to be supplied with the belt drive system.
- L. Stainless Steel Nameplate:** Shall be attached to the pump giving the manufacturer's model and serial number, rated capacity, head, speed and all pertinent data.
- M. Drive Motor:** Shall be ___ HP, ___ RPM, ___ volts, 3 phase, 60 hertz, 1.15 service factor, C-flange mounted, TEFC enclosure. The motor shall be sized for non-overloading conditions.
- N. Surface Preparation:** Solvent wash and a single coat of Themec 431 epoxy (except motor).
- O. OPTIONAL Premium Surface Preparation:** Solvent wash, sandblast, and coat with minimum 30 MDFT Themec Perma-Shield PL Series 431 epoxy (except motor).